

9/12/19

Sunapee Middle High School

List of Deficiencies Draft

Site

- Additional Athletic fields needed (additional soccer/ baseball or turf field and added softball plus track running lanes).
- Parking is tight for new drivers

Building:

- Sloped roof makes noise in wind and sun
- Skylights needed in biology
- FACS kitchen casework and equipment replacement required
- Acoustic issues with
 - Band Room
 - Library/ Physical Science
 - Administration suite and Nurses office
- Line of sight at girls locker room shower
- Gym HVAC performance issues